



DECLARATION

Issued 15-07-2020 Scope ---
 Report 2003754/3 Page 1 of 1
 PIN 0476CU3754

DECLARATION REGARDING VOKERA Ltd.

Test performed on LPG/NG see note below	Original Boiler Name	UK Market Name	Full Load Efficiency (% net)	Part Load Efficiency (% net)
NG	Vision PLUS 20S	Vision PLUS 20S	97,3	107,4
NG	Vision PLUS 25S	Vision PLUS 25S	97,5	107,2
NG	Vision PLUS 35C	Vision PLUS 35C	97,5	107,2
NG	Vision PLUS 30S	Vision PLUS 30S	97,5	107,2
NG	Vision PLUS 40C	Vision PLUS 40C	97,5	107,2

We declare that the full and part load efficiency test results detailed above have been obtained by means deemed to satisfy the Boiler Efficiency Directive (92/42/EEC). The water temperature criteria defined in the Boiler Efficiency Directive (see below) have been satisfied in obtaining these results.

Type of Boiler	Range of Power	Efficiency at rated output	Efficiency at part load
	KW	Average boiler-water temperature	Average boiler-water temperature
Standard boilers	4 to 400	70° C	≥ 50° C
Low temperature boilers ⁽¹⁾	4 to 400	70° C	40° C
Gas condensing boilers	4 to 400	70° C	30° C ⁽²⁾

¹ Including condensing boilers using liquid fuels.

² Temperature of boiler water supply.

Kiwa Cermet Italia S.p.a.

Industry Division Manager
 Maurizio Lorenzon

Kiwa Cermet Italia S.p.A.
 Società con socio unico, soggetta all'attività di direzione e coordinamento di Kiwa Italia Holding Srl

Via Cadrano, 23
 40057 Granarolo dell'Emilia (BO)

Unità locale
 Via Treviso 32/34
 31020 San Vendemiano (TV)

Tel +39. 0438 411755
 Fax +39.0438 22428
 E-mail: info@kiwacermet.it

www.kiwa.it
www.kiwacermet.it