CERTIFICATE

UK APPROVAL
Certificate Number: 1710702

Date Issued: 17th October 2017
Date Expired: 17th October 2022

Description: Range of wall mounted gas fired condensing combination boilers providing domestic hot water via a plate heat exchanger and pressurized central heating system incorporating an expansion vessel and pressure relief valve set at 3.0 bar. The supplies to the domestic hot water and primary are controlled via spherical valves. Maximum working pressure of the primary is 2.5 bar, maximum supply pressure of the domestic hot water 7.0 bar.

Product Designation: Clas One 24, Clas One 30, Clas One 38, Clas System One 18, Clas System One 24, Clas System One 30, Clas Net One 24, Clas Net One 30, Clas Net One 38, Cares One 24, Cares One 24,Cares One 30, Cares One 30, E-System One 24, E-System One 30, E-Combi One 24, E-Combi One 30, Alteas One Net 30, Alteas One Net 35, Genus One Net 24, Genus One Net 30, Genus One Net 35, E-Combi LPG One 24, E-Combi LPG One 30.

This is to certify that the above range of products manufactured / supplied by

Ariston Thermo SpA

has been tested and found to comply with the requirements of the Water Supply (Water Fittings) Regulations 1999 for England and Wales, the Water Byelaws 2000, Scotland and the Water Regulations Northern Ireland.

This certificate must be read in conjunction with the acceptance letter for this product.

This approval is intended for compliance with the above Regulations and must not be considered equivalent to the product certification provided by Kiwa N.V.

To comply with the Regulations and Byelaws all products require the correct installation. Details of the installation requirements (IRN's) can be obtained from the acceptance letter supplied with this certificate.

Applicable IRN's for this certificate – R001, R140, R360

Authorised Signature

Kiwa Watertec
(A Trading Division of
Kiwa Ltd)
Unit 26A
Rassau Industrial Estate
Ebbw Vale, Gwent, NP23 8XA
UNITED KINGDOM
Tel: 0044 (0) 1495 308185
Fax: 0044 (0) 1495 304496
Web: www.kiwa.co.uk

Certificate Issued to –
Ariston Thermo SpA
Viale Aristide Merloni,45
60044 Fabriano (AN)
Italy

kiwa approved product
UK WATER SUPPLY REGULATIONS